

# Water Heater Maintenance

## 2 Months:

Check water heater for leaks.

## 6 Months:

Flush out sediment from your water heater.

## 12 Months:

Inspect Anode Rod. Test T&P Valve.

Tape on to water heater.

---

Water Heater Maintenance Checklist										
6 month Flush: Inspection & Test:	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>
	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>
	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>
	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>	date: <input type="checkbox"/>

**LGE Prime Plumbing**  
**San Diego Ca.**  
**1 (858) 366-8735**